

October 16, 2007

CONTECH CONSTRUCTION PRODUCTS INC.  
TODD M. RIEBAU  
6441 ENTERPRISE LANE SUITE 116  
MADISON WI 53719

CONTECH CONSTRUCTION PRODUCTS INC.  
DON COLLING, PLANT SUPERINTENDENT  
PO BOX 236  
PORTAGE WI 53901

Re: Description: PIPES, ALUMINIZED STEEL (SEE ALSO STORMWATER DETENTION PIPING)  
Manufacturer: CONTECH CONSTRUCTION PRODUCTS INC.  
Product Name: CONTECH ALUMINIZED CORRUGATED STEEL PIPE W/WO TRENCHCOAT COATING;  
STORMWATER DETENTION PIPING  
Model Number(s): 2-2/3 x 1/2 CORRUGATED PIPE WITH H-12 HUGGER BANDS AND O-RING GASKETS  
OR 5 CORRUGATION BANDS (5C) WITH FLAT GASKETS: 12", 15", 18", 21", 24", 27",  
30", 33", 36", 42", 48", 54" AND 66"  
Product File No: 20070462

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2012.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain and vent use(s):
  - a. Storm sewer . . . . . gravity flow
- Joints between pipe and pipe or fittings and pipe must be made with H-12 double bolt, bar and strap with back up plate and profile gasket hugger band and o-ring gaskets or the 5-C band consisting of a five corrugated wide section of 2-2/3" x 1/2" rolled band with a strip of 2" x 1/8" roll caulk applied to the overlap section of the band and a 12" wide 3/8" flat neoprene gasket.
- The review undertaken by Commerce staff does not include review and/or approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product is approved for the following use:
  - Stormwater and clearwater subsurface detention system.
- When this product is installed as a subsurface detention system, the installation must be in accordance with the manufacturer's printed instructions. When there is a conflict between the manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.

Sizing of piping for stormwater and clearwater subsurface detention shall be made using hydraulic calculations as specified in manufacturer's instructions.

This approval supersedes the approval issued on June 17, 2003, under product file number 20030101.

CONTECH CONSTRUCTION PRODUCTS INC.

Page 2

October 16, 2007

Product File No: 20070462

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030101.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: [mike.beckwith@wi.gov](mailto:mike.beckwith@wi.gov)